

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION


P 1027

OWNER	NAME ANMARY HOMES, INC.		ADDRESS WOOD STREET, R #4, MAHOPAC, NEW YORK	
LOCATION OF WELL	CROSS HILL ROAD, LAKE CASSE, MAHOPAC, NEW YORK			
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify)			
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY <input type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) 150	DIAMETER (inches) six	WEIGHT PER FOOT 19 lb	<input type="checkbox"/> THREADED <input checked="" type="checkbox"/> WELDED <input checked="" type="checkbox"/> DRIVE SHOE <input type="checkbox"/> NO <input checked="" type="checkbox"/> WAS CASING GROUTED? <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED <input checked="" type="checkbox"/> COMPRESSED AIR		HOURS five	G.P.M. 5 1/2
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) forty two		DURING YIELD TEST (feet) <u>                    </u>	
SCREEN DETAILS	MAKE		LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	GRAVEL SIZE (inches) FROM (feet) TO (feet)

735 H

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	130	Drilling in overburden - clay and boulders
130		Hit solid rock at 130 ft.
130	150	Drilling in rock - setting casing - grouted
150	355	Drilling in rock - granite

Sketch exact location of well with distances, to at least two permanent landmarks.



SCALE 1"=30'

If yield was tested at different depths during drilling, list below	
FEET	GALLONS PER MINUTE

DATE WELL COMPLETED Sep 20/'72	DATE OF REPORT 10/2/72	WELL DRILLER (Signature) P. F. REAL & SONS, INC. <i>Malcolm H. Beale</i>
-----------------------------------	---------------------------	--